

ANEXO VI - Verificación Dinteles

	Dintel	Muro	Tipo	Luz de vano	Ri	Rd	M	Wnec	Cantidad	PN	Wex (unit)	Wex (total)	Valida	I	Flecha	Flecha Admisible	Valida
					(kg)	(kg)	(kgm)	(cm3)			(cm3)	(cm3)		(cm4)	(cm)	(cm)	
1	D104	15 - 16	Puerta	1.8	5382.5	5382.5	2422.1	173.0	2	PNi16	117	234	OK	935	0.21	0.36	OK
2	D101	18 - 19	Puerta	0.85	1778.0	1778.0	377.8	27.0	2	PNi8	19.5	39	OK	77.8	0.09	0.17	OK
3	D151	7 - 13	Puerta	1.57	5498.1	5498.1	2158.0	154.1	2	PNi14	81.09	162.18	OK	573	0.23	0.31	OK
4	D152	8 - 14	Ventana	1.75	2806.1	2806.1	1227.7	87.7	2	PNi12	54.7	109.4	OK	328	0.28	0.35	OK
5	D153	9 - 15	Ventana	1.75	3600.8	3600.8	1575.4	112.5	2	PNi14	81.09	162.18	OK	573	0.21	0.35	OK
6	D155	11 - 16	Ventana	1.75	3082.8	3082.8	1348.7	96.3	2	PNi12	54.7	109.4	OK	328	0.31	0.35	OK
7	D154	17 - 22	Puerta	0.85	1398.8	1398.8	297.2	21.2	2	PNi8	19.5	39	OK	77.8	0.07	0.17	OK
8	D002	4 - 5	Puerta	1.72	5552.6	5552.6	2387.6	170.5	2	PNi16	117	234	OK	935	0.19	0.34	OK
9	D003	6 - 7	Puerta	2.46	4477.5	4477.5	2753.7	196.7	2	PNi16	117	234	OK	935	0.44	0.49	OK
10	D001	9 - 10	Puerta	1.28	2778.2	2778.2	889.0	63.5	2	PNi10	34.2	68.4	OK	171	0.21	0.26	OK
11	D004	16 - 17	Puerta	1.74	4606.8	4606.8	2004.0	143.1	2	PNi16	117	234	OK	935	0.16	0.35	OK
12	D005	22 - 24	Ventana	2.8	12478.5	12478.5	8735.0	623.9	2	PNi24	354	708	OK	3060	0.50	0.56	OK
13	D006	26 - 27	Ventana	2.2	9012.6	9012.6	6081.7	434.4	2	PNi22	278	556	OK	3060	0.19	0.44	OK
14	D007	30 - 31	Puerta	3.26	14743.1	14743.1	12015.6	858.3	2	PNi26	442	884	OK	5740	0.55	0.65	OK
15	D008	32 - 33	Puerta	2.18	3970.1	3970.1	2163.7	154.5	2	PNi16	117	234	OK	935	0.27	0.44	OK
16	D009	34 - 35	Puerta	2.82	5135.6	5135.6	3620.6	258.6	2	PNi18	161	322	OK	1450	0.49	0.56	OK
17	D051	14 - 22	Ventana	1.75	10630.6	10630.6	4650.9	332.2	2	PNi20	214	428	OK	2140	0.17	0.35	OK
18	D052	23 - 39	Puerta	0.85	2435.3	2435.3	517.5	37.0	2	PNi8	19.5	39	OK	77.8	0.12	0.17	OK
19	D053	15 - 24	Ventana	1.75	7869.1	7869.1	3442.7	245.9	2	PNi18	161	322	OK	1450	0.18	0.35	OK
20	D054	25 - 40	Puerta	0.85	3496.1	3496.1	742.9	53.1	2	PNi10	34.2	68.4	OK	171	0.08	0.17	OK
21	D055	16 - 26	Ventana	1.75	6973.1	6973.1	3050.7	217.9	2	PNi16	117	234	OK	935	0.25	0.35	OK
22	D056	27 - 41	Puerta	0.85	2045.1	2045.1	434.6	31.0	2	PNi8	19.5	39	OK	77.8	0.10	0.17	OK
23	D057	17 - 28	Ventana	1.75	945.0	945.0	413.4	29.5	2	PNi10	34.2	68.4	OK	171	0.18	0.35	OK
24	D058	33 - 43	Puerta	0.85	1476.5	1476.5	313.8	22.4	2	PNi8	19.5	39	OK	77.8	0.07	0.17	OK
25	D059	19 - 34	Puerta	1.8	2412.2	2412.2	1085.5	77.5	2	PNi12	54.7	109.4	OK	328	0.27	0.36	OK